



State of North Carolina
Department of Environment, Health and Natural Resources

Winston-Salem Regional Office

James G. Martin, Governor
William W. Cobey, Jr., Secretary

Division of Environmental Management
Groundwater Section

Margaret Plemmons Foster
Regional Manager

August 7, 1992

New Grace Baptist Church
141 Apollo Circle
Archdale, NC 27263

Subject: Underground Storage Tank Closure,
New Grace Baptist Church, Corner Riverdale and
Kivett Drive, High Point, NC 27260

Gentlemen:

On December 14, 1990, we received the soil sample results and closure assessment from the underground storage tank closure at the subject location. As the implementing agency for the Federal Underground Storage Tank Program for the State of North Carolina, we have determined from review of your assessment that the UST system has been closed in accordance with NCAC Title 15A Subchapter 2N Section .0802 and .0803 and 40 CFR 280.71 and 280.72. However, this does not absolve you of any responsibility for contamination that may not have been detected or noted during the site assessment.

If you have any questions, please feel free to contact Tom Salley or me at the letterhead address or telephone number during the hours of 9:00 a.m. to 10:00 a.m. and 1:30 to 2:30 p.m.

Sincerely,

A handwritten signature in cursive script, reading "W. Waddell Watters".

W. Waddell Watters
Hydrogeologist II

WWW/dh

cc: ~~MSRO~~

Central Files - Guilford County

UNDERGROUND STORAGE TANKS (UST's)

New Grove Baptist Church

(CHECK APPROPRIATE RESPONSE)

REGULATED X

NONREGULATED _____

RELEASE CONFIRMED ? YES _____ NO X

CLEAN-UP INITIATED ? YES _____ NO _____

TANKS REMOVED ? YES X NO _____

RELEASE UNDER CONTROL ? YES _____ NO _____

CLEAN-UP COMPLETED ? YES _____ NO _____

